


1. ALL METAL SHALL BE STRUCTURAL GRADE AND BE GALVANIZED.
2. FRAME AND GRATE TO BE PER ALAMEDA COUNTY PUBLIC WORKS DEPARTMENT STANDARD DRAWINGS.
3. REQUIREMENT FOR AND LOCATION OF 4"Ø WEEP HOLES TO BE VERIFIED BY CONTRACTOR.
4. STEPS SHALL BE INSTALLED IN ALL INLETS 4'-0" OR GREATER IN DEPTH.
5. SLOPED FLOOR BY OTHERS IN FIELD.



DRAWING MAY NOT CONFORM TO THE
MOST CURRENT SPECIFICATION



FILE NAME: AGN-8.DWG

REVISÉ: MARCH 2016

www.oldcastleprecast.com

Copyright © 2016 **Oldcastle**[®] Precast, Inc.