


NOTES:

Penetrations shown here are for illustration purposes only. Actual penetrations required, and their locations, will vary according to customer needs.

GENERAL NOTES:

1. Concrete: 28 Day Compressive Strength $f'_c = 5,000$ psi
2. Steel Reinforcement: ASTM A-615, Grade 60
3. Cover to Steel-1" Minimum
4. Vaults are Designed to Meet ASTM C857 and ACI 318 with AASHTO HS-20 Loading
5. Construction Joint Sealed with Fuel Resistant Gasket Material CS-440

