



| Dia | A | B | C | T | H | L | S | R |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| in. | in. | in. | in. | in. | in. | in. | in. | in. |
| 42 | 78 | 56 | 35 | 4½ | 26 | 99 | 64 | 22 |
| 48 | 84 | 56½ | 27 | 5 | 31 | 98 | 64 | 22 |
| 54 | 90 | 63½ | 34 | 5½ | 36 | 98 | 64 | 24 |
| 60 | 96 | 72½ | 29 | 6 | 36 | 99 | 70 | 24 |
| 66 | 102 | 75 | 25 | 6½ | 40 | 99 | 74 | 24 |
| 72 | 108 | 78 | 21 | 7 | 42 | 99 | 78 | 24 |

GENERAL NOTES:

1. Reinforcing in the "C" Portion shall be the Same as Specified for Concrete Pipe ASTM C76 and AASHTO M170 Class III for the Size of Connection Pipe.
2. Concrete shall Have a Minimum Strength of 4000 psi.
3. Variations in Manufacturing Dimensions shall be as Called for in ASTM C76 and AASHTO M170.
4. Pipe to End Section Connection shall Match Joints of Standard Pipe Details.
5. Refer to Standard Details for Information not Listed on this Drawing.