

ALL CONCRETE SHALL HAVE A 28 DAY COMPRESSIVE STRENGTH OF 4500 psi.

REINFORCING STEEL SHALL COMPLY WITH ASTM A615 GRADE 60, A706 GRADE 60 OR A497 GRADE 70. BAR BENDING AND PLACEMENT SHALL COMPLY WITH THE LATEST ACI STANDARDS

STANDARD STRUCTURAL DESIGN IS BASED ON AASHTO HS 20 WHEEL LOADING


WATER TABLE IS AT 3'-0" BELOW GRADE FOR STANDARD STRUCTURAL DESIGN

THE STANDARD DESIGN IS BASED ON THE TOP AT ANY ELEVATION BETWEEN FINISHED GRADE AND 5'-0" BELOW GRADE. THE STRUCTURE SHALL BE PLACED ON A COMPACTED GRANULAR BASE TO INSURE UNIFORM DISTRIBUTION OF SOIL PRESSURES.


SPECIAL DESIGNS BASED ON OTHER LOADINGS OR DEEPER INSTALLATION DEPTHS ARE AVAILABLE ON REQUEST.

PIPE OPENINGS CAN BE PROVIDED IN THE SIZE AND LOCATIONS REQUIRED.

TOP SECTION



BOTTOM SECTION



APPROXIMATE TOP OR BOTTOM WEIGHTS	
2'-0" INSIDE	31000 LBS.
2'-6" INSIDE	33000 LBS.
3'-0" INSIDE	36000 LBS.
3'-6" INSIDE	38000 LBS.
4'-0" INSIDE	41000 LBS.

MINIMUM EXCAVATION
15'-4"x15'-4"

MAXIMUM WIDTH OPENING IS 144" WITH 132" MAXIMUM WIDTH IN ADJACENT WALL.



1900 Rilling Road San Antonio, TX 78214
Phone: (210) 923-4523 Fax: (210) 921-0473

1212-J

FILE NAME: 1212J2D.dwg

ISSUE DATE: March 2005

www.oldcastlesanantonio.com

12'-0"x12'-0"
2-PIECE JUNCTION BOX

Copyright 2005 Oldcastle Precast All Rights Reserved