

ALL CONCRETE SHALL HAVE A 28 DAY COMPRESSIVE STRENGTH OF 4500 psi.

REINFORCING STEEL SHALL COMPLY WITH ASTM A615 GRADE 60, A706 GRADE 60 OR A497 GRADE 70. BAR BENDING AND PLACEMENT SHALL COMPLY WITH THE LATEST ACI STANDARDS

STANDARD STRUCTURAL DESIGN IS BASED ON AASHTO HS 20 WHEEL LOADING

WATER TABLE IS AT 3'-0" BELOW GRADE FOR STANDARD STRUCTURAL DESIGN

THE STANDARD DESIGN IS BASED ON THE TOP AT ANY ELEVATION BETWEEN FINISHED GRADE AND 5'-0" BELOW GRADE.

THE STRUCTURE SHALL BE PLACED ON A COMPACTED GRANULAR BASE TO INSURE UNIFORM DISTRIBUTION OF SOIL PRESSURES.


SPECIAL DESIGNS BASED ON OTHER LOADINGS OR DEEPER INSTALLATION DEPTHS ARE AVAILABLE ON REQUEST. APPROXIMATE

PIPE OPENINGS CAN BE PROVIDED IN THE SIZE AND LOCATIONS REQUIRED.


TOP OR BOTTOM WEIGHTS
 2'-0" INSIDE 15000 LBS.
 2'-6" INSIDE 16500 LBS.
 3'-0" INSIDE 18000 LBS.
 3'-6" INSIDE 19500 LBS.
 4'-0" INSIDE 21000 LBS.

MINIMUM EXCAVATION
 11'-0"x13'-0"

TOP SECTION



BOTTOM SECTION



MAX. OPENING WIDTH COMBINATIONS

LONG WALL	SHORT WALL
120"	84"
108"	96"



Oldcastle Precast

1900 Rilling Road San Antonio, TX 78214
 Phone: (210) 923-4523 Fax: (210) 921-0473

810-J

FILE NAME: 810J2D.dwg

ISSUE DATE: March, 2005

www.oldcastlesanantonio.com

8'-0"x10'-0"

2-PIECE JUNCTION BOX

Copyright 2005 Oldcastle Precast All Rights Reserved