

NOTES:

- 1. DESIGN LOADINGS: A. 300 PSF PEDESTRIAN LOADING.
 - B. ASSUMED WATER TABLE = BELOW BOTTOM OF PRECAST
 - C. DRY LATERAL EARTH PRESSURE (EPF) = 45 PCF.
 - D. LATERAL LIVE LOAD SURCHARGE=80 PSF.
 E. NO LATERAL SURCHARGE FROM ADJACENT
 - BUILDINGS, WALLS, PIERS, OR FOUNDATIONS.
- 2. CONCRETE 28 DAY COMPRESSIVE STRENGTH SHALL BE 5,000 PSI MINIMUM.
- 3. STEEL REINFORCEMENT: REBAR, ASTM A-615 OR A-706, GRADE 60.
- 4. MESH REINFORCEMENT: ASTM C-1064, GRADE 80.
- 5. CEMENT: ASTM C-150 SPECIFICATION.
- 6. REQUIRED NATIVE ALLOWABLE SOIL BEARING PRESSURE = 2,500 PSF.
- 7. REFERENCE STANDARD: A. ASTM C 890 B. ASTM C 913
- 7. THIS STRUCTURE IS DESIGNED TO THE PARAMETERS NOTED HEREIN. PLEASE VERIFY THAT THESE PARAMETERS MEET PROJECT REQUIREMENTS. IF DESIGN PARAMETERS ARE INCORRECT, REVIEWING ENGINEER/AUTHORITY SHALL NOTIFY OLDCASTLE INFRASTRUCTURE UPON REVIEW OF THIS SUBMITTAL.
- 8. OVERSIZED HOLES TO ACCOMMODATE SPECIFIC PIPE TYPE MUST BE CONCENTRIC TO PIPE ID. AFTER PIPES ARE INSTALLED, ALL ANNULAR SPACES SHALL BE FILLED WITH A MINIMUM OF 3000 PSI CONCRETE FOR FULL THICKNESS OF PRECAST WALLS. PIPES ARE TO BE FLUSH WITH THE INSIDE SURFACE OF THE CONCRETE STRUCTURE.
- 9. CONTRACTOR RESPONSIBLE TO VERIFY ALL SIZES, LOCATIONS AND ELEVATIONS OF OPENINGS.
- 10. CONTRACTOR RESPONSIBLE TO ENSURE ADEQUATE BEARING SURFACE IS PROVIDED (I.E. COMPACTED & LEVEL PER PROJECT SPECIFICATIONS).
- 11. ALL EXTERIOR SURFACES SUPPLIED WITH "FORM FINISH
- 12. SYSTEM SHIPPED EMPTY. UNDERDRAIN, SOIL/FILTER MEDIA, DRAIN ROCK PROVIDED & INSTALLED BY OTHERS.
- 13. ADAPTORS/ANGLES AND EXTERNAL PIPING BY OTHERS.

